

All Water Systems with Active Arsenic Violations

DISTRICT NAME- DISTRICT NUMBER	SYSTEM NUMBER	SYSTEM NAME	POPULATI ON	SERVICE CONNECTION S	PWS CLASSIFICATIO N	IS THE PWS A SCHOOL OR DAYCARE THAT SERVES PEOPLE <18YRS.?	1ST ENF ACTION NO. ISSUED (Use the State Assign ID # in SDWIS)	1ST ENF ACTION ISSUE DATE (Status Date in SDWIS)	COMPLIANCE PLAN SUBMITTED? (Yes/No)	WAS A COMPLIANCE ORDER ISSUED? (Meets EPA's Formal Action Criteria)	2ND ENF ACTION NO. ISSUED (Use the State Assign ID # in SDWIS)	2ND ENF ACTION ISSUE DATE (Status Date in SDWIS)	DATE PWS MUST BE IN COMPLIANCE BY	BOTTLED WATER OR HAULED WATER PROVIDED (Yes/No)	POU/PO E PROVID ED (Yes/No)	FUNDING STATUS (If Applicable)	PROBLEM DESCRIPTION	PROPOSED SOLUTION	NOTES	RTC?	RTC DATE	RTC BASK
Klamath-01	5301002	Lewiston Community Services District (acquired system from Lewiston Valley Water Company in June 2012)	150	37	COMMUNITY	NO	0901005	2/24/2009	NO	YES			No specific deadline was defined.			Have Prop 84 construction grant. Construction has begun. Notice to proceed was issued on 7/7/14. Construction completion deadline is 7/7/15.	Source (surface water) exceeds MCL. RAA of 29.2 ug/l as of 1st qtr 2009.	Received Prop 84 construction funding. Will construct new water intake away from source of arsenic.		NO		
Lassen-02	3210011	Plumas Eureka CSD	1785	547	COMMUNITY	NO	0902003	2/26/2009	YES	YES	9502007	11/13/2014	11/1/2016	No	No	District plans to apply for both SRF and Rural Development funding to fund proposed solution.	Well 2 exceeds MCL	Construct new well and blend with Well 2 to meet arsenic standard. If arsenic level in new well is not low enough to provide blending treatment, then construct coagulation/filtration treatment at Well 2		No		
Lassen-02	4600019	Sierra Co. W.W.D #1 Calpine	225	142	COMMUNITY	NO	0902005	2/26/2009	YES	YES	1202017	11/18/2011	Another enforcement action with compliance deadline needs to be issued.	No	No	System performed an income survey and may be eligible for grant funding. They are planning to pursue both SRF and Rural Development funding.	Well 2 exceeds MCL	District is in process of completing a pilot study to determine the best arsenic treatment alternative.		No		
Monterey-05	3500570	B & R Farms	25	14	NTNC	NO	05-14R-002	5/30/2014	YES	YES			31-Jul-16	NO	NO	not applicable	Arsenic over MCL	treatment	on quarterly PN			
Santa Barbara-06	4210009	Cuyama CSD	820	223	COMMUNITY	NO	1006007	12/9/2009		YES						Funding project nearing completion. Arsenic treatment plant has been online since September 2014. Treated water meets the arsenic standard.	Wells 01 and 02	PN required, existing treatment plant was re-engineered and construction was completed in September 2014.				
Hollywood-07	1910246	Land Projects Mutual Water Company	1500	539	COMMUNITY	NO	0907052	1/6/2009	NO	YES	1207062	4/18/2012		NO	NO	N/A	Wells 1, 3 and 8 arsenic RAA exceeded the arsenic MCL of 10 ug/L.	PN and quarterly monitoring required. Well 8 is expected to RTC in the 4th Q 2014 or 1st Q 2015. The Company is planning to drill two new shallow wells to replace Wells 1 and 3.	The Company has modified Well 8 casing perforations and reduced its pumping rate from 1000 gpm to 600 gpm, the most recent arsenic sampling results was 6.5 ug/L.	NO		
Stockton-10	5010008	City of Hughson	6082	1779	COMMUNITY	NO	0910024	1/5/2009	Yes	YES			7/1/2015			Applied for SRF Planning Loan	Two of 5 wells exceed As MCL with As 11-17 ug/L.	Planning to treat at least 1 well.				
Stockton-10	5010009	Keyes CSD	4575	1450	COMMUNITY	NO	0910018	1/5/2009	Yes	YES	910018	1/14/2014	12/31/2016	NO	NO	Completing P&S, should be complete by 2/28/15	Three of 4 wells exceed As MCL with As 13- 16 ug/L.	Centralized Treatment Plant	CO Addendum was issued to the original CO, not a second CO			
Merced-11	2010007	Hillview Water Company-Oakhurst/Sierra Lakes	3006	1026	COMMUNITY	NO	0911021	1/26/2009	YES	YES				NO		Prop 84 funding executed and in process	Eight wells exceed the arsenic MCL.	Hillview has applied for Prop 84 funds to construct	Construction project is underway.			
Merced-11	2010801	Valley State Prison	4000	667	COMMUNITY	NO	0911007	3/27/2009	YES	YES	9611008	12/1/2014	10/30/2015	NO			Well Nos.1 & 2 exceeds arsenic MCL	Blending water from Well 1 & 2 with Well 401 (CCWF)	Blending facilities should be completed by March 31, 2015.			
Merced-11	2210900	Cedar Lodge Resort	64	10	NTNC	NO	0911011	4/21/2009	YES	YES				NO			Wells Nos. 5 and 6 exceed the arsenic MCL	Blending plan	No violation since 1st qtr 2014. For reliability purposes, WS is in process ofoptimizing blending operations.			
Merced-11	2400053	El Nido Mobile Home Park	250	49	COMMUNITY	NO		6/25/2002							YES		Wells 3 & 4 exceeds arsenic MCL	Each service connection has a POU RO device which reduces the arsenic level to below 10 ug/L	Inherited from Merced County (LPA). The system has reliably produced water that complies with the arsenic MCL with the use of POU devices.			
Merced-11	2400165	Foster Farms Delhi Feedmill	200	1	NTNC	NO											Arsenic is above MCL in the only active well.	System is monitoring other available wells to determine potential for blending treatment.	No compliance order issued by LPA, SWRCB investigating			
Merced-11	2410004	City of Livingston	14894	3121	COMMUNITY	NO	9611009	5/16/2013	YES	YES						City has submitted an application for funding thru SDWSRF.	Well #13 produces water with arsenic above MCL.	The system has submitted a corrective action plan. They are exploring treatment options.				
Merced-11	2010012	Hillview Water Company-Raymond	290	89	COMMUNITY	NO	1211020	8/7/2012	YES	YES						Prop 84 funding executed and in process	Wells 10 & 11 exceeds Arsenic MCL	Provide treatment	Construction project is underway.			
Merced-11	2210937	Mariposa County Public Works Dept	135	5	NTNC	NO	1011005	11/1/2013	No	YES				YES			Well 2 exceeds Arsenic MCL	Working with consulting engineers on treatment options				
Visalia-12	1500378	Maher Mutual Water Company	192	50	COMMUNITY	NO	0919022	1/23/2009		YES							Well 01 in violation of arsenic MCL, RAA 0.021 mg/L	Maher MWC is working on a SRF application for cons		NO		
Visalia-12	1500493	El Adobe Property Owners Association, Inc.	200	77	COMMUNITY	NO	0919014	1/23/2009		YES							Well 02 is in violation of the arsenic MCL, RAA 0.023 mg/L	Proposal for developing an intertie with Lamont PU		NO		
Visalia-12	1500585	Oasis Property Owners Association	100	38	COMMUNITY	NO	0919013	1/23/2009		YES										NO		
Visalia-12	1502383	Nord Road Water Association	39	16	COMMUNITY	NO	0919041	1/23/2009		YES							Well 01 is in violation of the arsenic MCL, RAA 0.016 mg/L	Nord Road WA is planning to consolidate with Vaughn		NO		
Visalia-12	1510001	Arvin CSD	11847	3446	COMMUNITY	NO	EPA NO. PWS-AO-2008-6022	10/23/2008		YES						Prop. 84 project-NOAA	5 (6?) wells exceed	Qtrly PN and sampling required		NO		
Visalia-12	1510005	City of Delano	53855	8829	COMMUNITY	NO	EPA NO. PWS-AO-2008-6020	9/25/2008		YES						Has SRF funding commitment;SRF project - NOAA	9 wells exceed	Qtrly PN and sampling required		NO		
Visalia-12	1510012	Lamont PUD	13296	3475	COMMUNITY	NO	0912012	12/18/2008		YES							3 wells exceed	Qtrly PN and sampling required		NO		
Visalia-12	1510024	Greenfield CWD	6500	2522	COMMUNITY	NO	1012013			YES										NO		
Visalia-12	1610001	Armona CSD	3239	1301	COMMUNITY	NO	EPA NO. PWS-AO-2008-6021	9/25/2008		YES						SRF project - NOAA	2 wells exceed	Qtrly PN and sampling required		NO		
Visalia-12	1610005	City of Lemoore	24500	6117	COMMUNITY	NO	0912018	12/18/2008		YES						SRF project - NOAA	3+ wells exceed	Qtrly PN and sampling required		NO		
Visalia-12	1610009	Kettleman City CSD	1499	358	COMMUNITY	NO	0912018	1/12/2009		YES						SRF project - Possible Prop. 84??	2 wells exceed	Qtrly PN and sampling required		NO		
Visalia-12	5410009	Pixley PUD	2793	800	COMMUNITY	NO	0912015	1/23/2009		YES						Prop. 84 project - NOAA	3 wells exceed	Qtrly PN and sampling required		NO		
Visalia-12	5410024	Richgrove Community Services	3330	528	COMMUNITY	NO	0912022	5/1/2009		YES										NO		
Visalia-12	5410050	Alpaugh JPA	1091	340	COMMUNITY	NO	0912002	12/18/2008		YES						Prop. 84 project-NOAA	1 well exceeds	Qtrly PN and sampling required		NO		
San Bernardino-13	2610003	Bridgeport PUD	3000	227	COMMUNITY	NO	0913027	2/13/2009	Yes	YES	1314R001	1/8/2014		No	No	On SRF PPL.		PN and quarterly monitoring required. Considering Adsorption treatment for removal of arsenic		No		
San Bernardino-13	3610705	US Army Fort Irwin National Training Center	16000	5690	COMMUNITY	NO	0913027	2/13/2009	Yes	YES	1312O001	2/24/2012	9/30/2015	No	No			System required to monitor by 4/30/08. EDR Treatment plant under construction, to be completed Summer 2015		No		
Sonoma-18	4900855	West Field Community	75	29	COMMUNITY	NO	EPA NO. PWS-AO-2008-6016	8/25/2008	YES	YES				NO	NO	Included in City of Santa Rosa Regional Prop 84 project	Only well arsenic RAA = 22 ug/L.	Coordinating consolidation with the City of Santa Rosa	expected to use P84 funding to consolidate with City of Santa Rosa			

All Water Systems with Active Arsenic Violations

Sonoma-18	4900575	Loch Haven Mutual Water Company	50	19	COMMUNITY	NO	0918023	12/31/2008	YES	YES			NO	Yes	No SRF application	Only well arsenic RAA = 14 ug/L.	Work with existing POU installs	POU compliance will be achieved via CO				
Sonoma-18	4900643	Mount Weske Estates Mutual Water Company	62	21	COMMUNITY	NO	0918007	6/2/2009	NO	NO			NO	Yes	No SRF application	Only well arsenic RAA = 44 ug/L.	Work with existing POU installs	POU compliance will be achieved via CO				
Sonoma-18	4900676	Sequoia Gardens Mobile Home Park	300	191	COMMUNITY	NO	0918003	1/21/2009	YES	YES			YES	NO	Included in City of Santa Rosa Regional Prop 84 project	Only well arsenic RAA = 14 ug/L.	Coordinating consolidation with the City of Santa Rosa	expected to use P84 funding to consolidate with City of Santa Rosa				
Sonoma-18	4900815	Palms Inn	300	2	NTNC	NO	0918008	1/21/2009	NO	YES	1018012	5/20/2010	6/3/2012	NO	No	No SRF application	Only well arsenic RAA 16 ug/L.	Consolidate with Santa Rosa or bankrupt.	Proceeding to trial			
Sonoma-18	4900878	Santa Rosa Golf & Country Club	50	5	NTNC	NO	9518002	6/4/2013	YES	YES			12/31/2014	YES	NO	Not applied	only well arsenic RAA = 85 ug/L and October 2014 results 110 and 120 ug/L.	adsorption treatment or interconnection. Interconnection is preferred, but if other water system doesn't agree, treatment plan has been approved and can be installed within 120 days.	after October 2014 sample was verified, system was put on a Do no Drink order until hauled water was available. System plans to continue hauling water daily until permanent solution is installed. Do Not Drink was lifted upon confirmation that hauled water is only source and well was disconnected. currently negotiating with Willowside Mutual Water Company for consolidation. Decision will be final December 17, 2014.	NO		
Sonoma-18	4900897	Rodney Strong Vineyards	100	1	NTNC	NO	0818009	5/2/2008	YES	YES				NO	Yes	No SRF application	Both wells exceed arsenic MCL. Well 3 arsenic RAA = 50 ug/L. Well 4 arsenic RAA = 15 ug/L.	POE installed		YES		
Sonoma-18	4901195	Moorland Avenue Apartments	64	16	COMMUNITY	NO	0918013	1/27/2009	YES	YES				no	no	Included in City of Santa Rosa Regional Prop 84 project	Only well arsenic RAA = 13 ug/L.	Coordinating consolidation with the City of Santa Rosa	expected to use P84 funding to consolidate with City of Santa Rosa			
Tehachapi-19	1500290	Edgemont Acres Mutual Water Company	600	148	COMMUNITY	NO	0919027	3/26/2009	YES	YES				Yes	No	SRF planning loan application was determined to be incomplete overt two years ago.	Well 02 in violation of arsenic MCL, RAA 0.200 to 0.240 mg/L; has been completely on AVEK Water since 1/1/2012	Water Company wants to install dual plumbed system-one for outside irrigation and one for domestic use with arsenic treatment	Temporary RTC - using AVEK water since 01/01/12			
Tehachapi-19	1500364	Kernvale Mutual Water Company	50	25	COMMUNITY	NO	0919030	1/23/2009	YES	YES				No	No	P84 construction funding application received for consolidation with Erskine Creek Water Company	Well 01 in violation of arsenic MCL; the well ran dry in 2013; buying water from Erskine Creek WC via emergency intertie	Consolidation with Erskine Creek Water Company	Well is dry; emergency tie-in with Erskine Creek since 10/17/2013			
Tehachapi-19	1500405	Aerial Acres Water System	114	60	COMMUNITY	NO	0919012	1/23/2009	YES	YES				No	No	P84 construction funding project in progress; 75% completed.	Well 02 in violation of arsenic MCL, 3rd qtr 2014 RAA 0.030 mg/L	Drill a new well and arsenic removal treatment using adsorption				
Tehachapi-19	1500424	Land of Promise Mutual Water Association	190	61	COMMUNITY	NO	0919019	1/23/2009	YES	YES				No	No	Part of Rosamond CSD Regional Consolidation P84/SRF Planning Project	Wells 03, 04, 05 & 06 are in violation of the arsenic MCL, 3rd qtr 2014 RAA 0.017 mg/L.	Consolidation with Rosamond CSD				
Tehachapi-19	1500426	Rosa Villa Apartments	100	32	COMMUNITY	NO	0919021	1/23/2009	YES	YES				No	No	Part of Rosamond CSD Regional Consolidation P84/SRF Planning Project	Well 01 is in violation of the arsenic MCL, 3rd qtr 2014 RAA 0.010 mg/L	Consolidation with Rosamond CSD				
Tehachapi-19	1500436	Hungry Gulch Water System	30	17	COMMUNITY	NO	0919015	1/23/2009	YES	YES				No	No	P84 planning project in progress	Well 02 is in violation of the arsenic MCL, 3rd qtr 2014 RAA 0.082 mg/L	Drilling a new well and POU/POE also being evaluated; Consolidation of Boulder Canyon with Hungry Gulch MWC				
Tehachapi-19	1500442	Sunset Apartment Water System	37	20	COMMUNITY		0919015	1/23/2009	YES	YES				No	No	Part of North Edwards Water District's P84 construction funding project; 35% completed.	Well 01 in violation of arsenic MCL,3rd qtr 2014 RAA 0.040 mg/L	Consolidation with North Edwards Water District	System re-named & re-activated Q2 2013, 0.040 mg/L RAA reported in SDWIS			
Tehachapi-19	1500449	Fourth Street Water System	35	24	COMMUNITY	NO	0919011	1/23/2009	YES	YES				No	No	P84 construction funding application received; waiting for issuance of construction funding agreement.	Well 01 and Well 02 are in violation of the arsenic MCL, 3rd qtr 2014 RAA 0.014 mg/L	Drill a new well and storage tank				
Tehachapi-19	1500455	William Fisher Memorial Water Company	51	17	COMMUNITY	NO	0919028	1/23/2009	YES	YES				No	No	Part of Rosamond CSD Regional Consolidation P84/SRF Planning Project	Well 02 is in violation of the arsenic MCL, 3rd qtr 2014 RAA 0.019 mg/L	Consolidation with Rosamond CSD				
Tehachapi-19	1500458	RS Mutual Water Company	25	25	COMMUNITY	NO	0919014	1/23/2009	YES	YES				No	No	In pipeline to get P84 funding agreement	Well 01 is in violation of the arsenic MCL, 3rd qtr 2014 RAA 0.011 mg/L	Consolidation with CWS-Kernville				
Tehachapi-19	1500461	Fountain Trailer Park Water	68	32	COMMUNITY	NO	0919019	1/23/2009	YES	YES				No	No	Part of North Edwards Water District's P84 construction funding project; 35% completed.	Well 01 is in violation of the arsenic MCL, 3rd qtr 2014 RAA 0.087 mg/L	Consolidation with North Edwards Water District				
Tehachapi-19	1500485	Antelope Valley Mobile Estates	84	28	COMMUNITY	NO	0919005	1/23/2009	YES	YES				No	No	Part of Rosamond CSD Regional Consolidation P84/SRF Planning Project	Well 02 is in violation of the arsenic MCL, 3rd qtr 2014 RAA 0.009 mg/L	Consolidation with Rosamond CSD				
Tehachapi-19	1500521	Boulder Canyon Water Association	30	27	COMMUNITY	NO	0919014	1/23/2009	YES	YES				No	No	Part of Hungry Gulch P84 planning project; plan to consolidate with Hungry Gulch	Well 01 and Well 02 are in violation of the arsenic MCL, 3rd qtr 2014 RAA 0.022 mg/L	Consolidation with Hungry Gulch MWC				
Tehachapi-19	1500525	Lakeview Ranchos Mutual Water	120	74	COMMUNITY	NO	0919012	1/23/2009	YES	YES				No	No	P84 planning project in progress	Well 01 and Well 03 are in violation of the arsenic MCL, 3rd qtr 2014 RAA 0.047 mg/L	Drill a new well; blending treatment and/or emergency intertie with CWS-Southlake				
Tehachapi-19	1500540	Piñon Valley Water Company	75	37	COMMUNITY	NO	0919013	1/23/2009	YES	YES				No	No		Well 01 is in violation of the arsenic MCL, 3rd qtr 2014 RAA 0.011 mg/L; arsenic removal treatment installed; in the process of being permitted	Arsenic removal treatment and possible emergency intertie with QVWD				
Tehachapi-19	1500571	Lucky 18 on Rosamond, LLC	58	60	COMMUNITY	NO	0919011	1/23/2009	YES	YES				No	No	Part of Rosamond CSD Regional Consolidation P84/SRF Planning Project	Well 01and Well 02 are in violation of the arsenic MCL, 3rd qtr 2014 RAA 0.026 mg/L	Consolidation with Rosamond CSD				
Tehachapi-19	1502154	Lakeside School	800	1	NTNC	YES	0919009	1/23/2009	YES	YES				Yes	No	2nd P84/SRF planning funding agreement issued; project in progress	Well 02 is in violation of the arsenic MCL, 3rd qtr 2014 RAA 0.017 mg/L	Drill a new well and arsenic removal treatment evaluation if test well is not successful				
Tehachapi-19	1502231	Rosamond School Water System	1600	3	NTNC	YES	0919016	1/23/2009	YES	YES				Yes	No	Part of Rosamond CSD Regional Consolidation P84/SRF Planning Project	3rd qtr 2014 RAA 0.011 mg/L	Consolidation with Rosamond CSD				
Tehachapi-19	1502244	Semi Tropic School Water System	320	6	NTNC	YES	0919013	1/23/2009	YES	YES				Yes	No	SRF construction project for consolidation with Lost Hills Utilities District in progress	Well 01 is in violation of the arsenic MCL, 3rd qtr 2014 RAA 0.020 mg/L	Consolidation with Lost Hills Utility District				

All Water Systems with Active Arsenic Violations																						
Tehachapi-19	1502569	First Mutual Water System	40	15	COMMUNITY	NO	0919020	1/23/2009	YES	YES			No	No	Part of Rosamond CSD Regional Consolidation P84/SRF Planning Project	Well 01 is in violation of the arsenic MCL, 3rd qtr 2014 RAA 0.017 mg/L	Consolidation with Rosamond CSD					
Tehachapi-19	1502724	Quail Valley Water District-Eastside System	50	19	COMMUNITY	NO	0919007	1/23/2009	YES	YES			No	No	P84 planning project completed; invitation for p84 construction funding issued in Nov. 2014	Well 01 and Well 02 are in violation of the arsenic MCL, 3rd qtr 2014 RAA 0.074 mg/L	Drill a new well and installation of iron and manganese removal treatment					
Tehachapi-19	1502744	60th Street Association Water System	44	9	COMMUNITY	NO	1119001	7/19/2011	YES	YES			No	No	Part of Rosamond CSD Regional Consolidation P84/SRF Planning Project	Well 01 is in violation of the arsenic MCL, 3rd qtr 2014 RAA 0.010 mg/L	Consolidation with Rosamond CSD					
Tehachapi-19	1510002	Boron Community Services District	2500	631	COMMUNITY	NO	0919010	1/23/2009	YES	YES			No	No	SRF planning agreement issued	Well 15 with 50% Blended Water from AVEK is in violation of the arsenic MCL, 3rd qtr 2014 RAA 0.038 mg/L	Planning to drill a new well and evaluate treatment if well is not successful					
Tehachapi-19	1510014	Mojave Public Utility District	3900	1306	COMMUNITY	NO	0919023	1/23/2009	YES	YES			No	No	P84 construction funding project in progress; over 90% completed	Well 07and Well 08 are in violation of the arsenic MCL, 3rd qtr 2014 RAA 0.015 mg/L	Arsenic removal being installed					
Tehachapi-19	1510016	Rand Communities Water District	344	295	COMMUNITY	NO	0919034	1/23/2009	YES	YES			No	No	P84 planning project in progress	Well 01 and Well 02 are in violation of the arsenic MCL, 3rd qtr 2014 RAA 0.021 mg/L	Drill a new well and evaluate treatment if the new well is not successful					
Tehachapi-19	1510027	Desert Lake Community Service District	600	233	COMMUNITY	NO	0919009	1/23/2009	YES	YES			No	No	Waiting for issuance of SRF Planning project pending adoption of new water rates by the DLCSD board	Well 02 is in violation of the arsenic MCL, 3rd qtr RAA 0.032 mg/L.	Drill a new well and evaluate treatment if the new well is not successful					
Tehachapi-19	1510052	North Edwards Water District	597	222	COMMUNITY	NO	0919015	1/23/2009	YES	YES			No	No	P84 construction funding project in progress; 35% completed	Well 01 and Well 02 are in violation of the arsenic MCL, 3rd qtr 2014 RAA 0.031 mg/L	Drill a new well and arsenic removal treatment using coagulation and filtration					
Tehachapi-19	1510054	Pinon Pines Mutual Water Company	700	242	COMMUNITY	YES	1219014	10/11/2011	YES				No	No	P84 planning project is almost complete; arsenic blending treatment to be provided	Arsenic MCL violation of Well 5. 3rd qtr 2014 RAA 0.012 mg/L	Arsenic blending treatment in a tank					
Valley-21	0600008	Colusa County Water District #1-Grimes	500	104	COMMUNITY	NO	0921006	1/5/2009	YES	YES					SRF construction project kicked back to Planning. Planning Application being prepared right now	Well #1 arsenic results between 23 ug/l and 30 ug/l since year 2000.	investigating possibility of new wells or treatment	Have P84 bottled water grant				
Valley-21	0600011	Del Oro Water Company - Walnut Ranch	182	78	COMMUNITY	NO	1021006	7/15/2010	NO	YES					SRF planning consolidation project to City of Colusa underway -	RAA of well = 11.0 ug/l	Consolidation with City of Colusa	water provided to consumers meets MCL,, being purchased thru emergency intertie with Colusa. Can't say RTC until City takes over water svstem				
Valley-21	5100107	Sutter Co. WWD #1 Robbins	336	94	COMMUNITY	NO	0921006	1/2/2009	YES	YES					P84 planning study underway	Treated water from iron / manganese plant exceeds MCL	new well with new treatment					
Valley-21	5100109	Wildwood MWC	350	48	COMMUNITY	NO	510001	7/18/2012	YES	YES					P84 consolidation project to Yuba City underway	Arsenic level exceeds MCL	consolidate to City of Yuba City		NO			
Valley-21	5100149	Barry Elementary School	560	1	NTNC	YES	0921012	1/5/2009	YES	YES					P84 planning study underway	Well water exceeds MCL, only one active well	treatment	will treat old well, new wells had high Fe / Mn. Have P84 bottled water grant				
Valley-21	5210003	Los Molinos Community Services District	1500	358	COMMUNITY	NO	0921021	1/2/2009	YES	YES					P84 planning study underway	One of the systems three wells exceeds 10 ug/l. Other 2 wells comply.	blending, treatment, or new well					
Valley-21	5100145	Winship Elementary School	38	1	NTNC	YES	21-13R-003	9/30/2013	YES	YES					Waiting for funding agreement for SRF planning project	system has one well with arsenic in high teens	planning study to begin	providing info for them apply to P84 bottled water				
Fresno-23	1000238	Camden Trailer Park	90	25	COMMUNITY	NO	0923438	9/25/2009		YES				YES	Operator submitted Univ Preap during Sept 2009.	As exceedance based on 2 quarterly samples in one well.	POU installation using P84 Part 1 grant funding	POU units have been installed on 26 connections. RTC after 4 QRAA < MCL	NO			
Fresno-23	1000369	Zonneveld Dairy	141	34	COMMUNITY	NO	0923002	7/29/2009		YES			YES		P84 Planning study underway.	As exceedance based on 2 quarterly samples in one well. Second well will violate as soon as 2nd Q sample collected.	POU installation using P84 planning study.	3 units have been installed and are in process of 1-year pilot study.	NO			
Fresno-23	1000042	FCWWD#40 Shaver Springs	172	69	COMMUNITY	NO	1023361	4/26/2010	NO	YES					SRF planning FA issued, pending execution	1 of 2 wells exceed MCL.		SRF planning study FA issued 11/21/14	NO			
Fresno-23	1000053	Lanare CSD	400	154	COMMUNITY	NO	0923296	5/18/2009		YES			YES		P84 planning study completed 6/27/14. SRF construction ap received & being processed by DFA. Project cost is apx \$6M for two new wells and distribution replacement. System invited for both SRF and P84 funding.	2 of 2 wells exceed; treatment installed on one well is not being operated due to unaffordable O&M costs; System has demonstrated inadequate TMF	Construct 2 replacement wells.	SRF planning study demonstrated 2 new wells viable. SRF Construction ap submitted and being processed by DFA	NO			
Fresno-23	1000072	Shaver Lake Pt. No. 2	210	93	COMMUNITY	NO	03-23-14R-002	1/7/2014	NO	YES						As exceedance in one of three wells		Water system evaluating alternatives. NOT using state funding.	NO			
Fresno-23	1000580	Campos Bros Farms (Walnut)	150	9	NTNC	NO	1123003	6/10/2011	NO	YES					System not eligible.	Exceeds the arsenic MCL in sole source.	Unknown	Proposed piloting treatment but vendor nonresponsive.	NO			
Fresno-23	1000584	True Organic Products	42	1	NTNC	NO	1223002	12/15/2011	NO	YES					Ineligible	Arsenic MCL exceedance.	Unknown	Proposed piloting treatment but vendor nonresponsive.	NO			
Fresno-23	1000602	Baker Commodities	60	6	NTNC	NO	03-23-14R-003	4/22/2014	NO	YES						Well 03 exceed As MCL (14.7 ppb)	Evaluating treatment					
Fresno-23	1009091	Olam Spices & Vegetables	125	7	NTNC	NO	1123002	3/1/2011	NO	YES					System not eligible.	Sole source exceeds the arsenic MCL.	Arsenic removal treatment installed	Pending 4QRAA to RTC.	NO			
Fresno-23	1010028	Riverdale Public Utility District	2416	950	COMMUNITY	NO	EPA NO. PWS-AO-2008-6018	9/25/2008	YES	YES					P84 planning study completed. P84/SRF construction project underway.	2 untreated wells exceed	Construction of replacement well.	Construction project phased to first drill new well, then will install treatment oif well does not meet As MCL.	NO			
Fresno-23	1010039	Caruthers CSD	2103	672	COMMUNITY	NO	0923003	1/15/2009	YES	YES					P84 planning study completed. P84 construction project underway.	3 of 4 wells exceed; avg of 14 to 24 ug/L	Construction of new well, blending, treatment as needed		NO			
Fresno-23	1009051	Cantua Creek Vineyards	50	23	COMMUNITY	NO	2015-9600024	10/7/2014	NO	YES		7/1/2017	NO	NO	Ineligible	Well exceed As MCL	Compliance Plan due 1/31/2015	We believe this system will participate in a consolidation project currently in an SRF planning study by FCSA #30 & 32 (1000019 & 1000359)	NO			
Tulare-24	5410033	Pratt MWC	1500	277	COMMUNITY	NO	1012021	2/1/2010	YES	YES			NO		P84 project - construction	ARSENIC						
Tulare-24	5400544	Allensworth CSD	400	110	COMMUNITY	YES	11036892	12/21/2010	YES	YES			NO		P84 project - planning	ARSENIC	COMPLIANCE ORDER ISSUED 12/21/2010 (CO #: 2010-39)	WELL 02 EAST & WELL 03 WEST				
Tulare-24	5400713	OAK VALLEY SCHOOL	300	7	NTNC	YES	1103922	8/22/2011	YES	YES			NO		SRF project - construction	ARSENIC	COMPLIANCE ORDER ISSUED 10/7/2008 (CO #: 2008-10)	WELL 01				
											ALL SYSTEMS										12/9/2014	

All Water Systems with Active Arsenic Violations																			
Tulare-24	5400754	SOUTH KAWEAH MUTUAL	300	105	COMMUNITY	NO	1204206	4/23/2012	YES	YES			NO			ARSENIC	COMPLIANCE ORDER ISSUED 4/20/2009 (CO #: 2009-07)	WELL 01 (DRY), WELL 02 & WELL 03 (OUT OF SVC)	
Tulare-24	5403054	PFFJ, LLC	87	11	NTNC	NO	CC0002534	3/5/2008	YES	YES	CC0003820	6/11/2011	YES			ARSENIC	COMPLIANCE ORDER ISSUED 3/5/2008 (CO #: 2008-03); ALSO ON BOTTLED WATER - EXPIRES JUN 2013	WELL 01 DEEP - NEED TO REISSUE CO & WELL 04 - NEED TO REISSUE CO	
Contra Costa LPA-37	0706028	Knightsen Elementary School	600	3	NTNC	YES	003-09	10/16/2009	YES	YES			NO		Funding approved for planning.	Well #3	Evaluation to blend sources to reduce arsenic level to below MCL. Two of the thee wells are below the MCL. Funding application approved.		
Contra Costa LPA-37	0707602	Beacon West	45	17	COMMUNITY	YES	002-09	9/4/2009	YES	YES			NO		N/A	Naturally Occurring	Water system has conducted pilot testing and determined that treatment may be cost prohibitive. The water system is proposing to construct a new well at a shallower depth and has recently obtained grant funding for the constuction of a new well.		
Contra Costa LPA-37	0707615	Doubletree Ranch HOA	49	18	COMMUNITY	NO	001-09	4/9/2009	YES	YES			NO		Funding Approved for construction of a new well.	Naturally Occurring	The water system has started pilot testing, however there were production problems with one of the two wells going dry. The water system has been focusing their efforts on restoring the water supply. The water systems is currently evaluating the use of POE and POU treatment options. The water system is not seeking any funding assistance at this time.		
El Dorado LPA-39	0900102	Gold Beach Park	100	50	COMMUNITY	NO	COM 2009-03 (not in PICME)	11/9/2009		YES						High Arsenic in Well #3.	Issuing Do Not Drink Notices in annual CCR. Last sanitary survey was 8/2011.		
El Dorado LPA-39	0900210	Millers Hill School	120	2	NTNC	YES										Wells #3 & #4 testing high for Arsenic and Well #4 is going dry.	School applied for funding to drill a new well.		
Imperial - 43	1300556	Mulberry Union School	105	5	NTNC	Yes	CC0000223	1/21/2014	Yes	YES	No		Yes			Arsenic detected in artesian well	Installed lead/lag arsenic removal media filters	Running annual average has not returned to be below the Arsenic MCL	No
Inyo LPA-44	1400036	Keeler CSD	180	88	COMMUNITY	NO	1100042	12/10/2010	YES	YES			No	Yes	FA Issued	Arsenic MCL. Currently using POU devices but not installed at all service connections. Running annual average is at 0.081 mg/L at well. POU devices are at ND.	Public notification		No
Inyo LPA-44	1400037	Foothill Lone Pine MHP, LLC	100	48	COMMUNITY	NO	100003	5/10/2010	YES	YES	1200002	10/7/2011	No	No	Privately owned mobile home park.	System exceeds Arsenic MCL.	Drilled new well, but it exceeds Uranium MCL. Istalled AdEdge arsenic treatment plant w/o plan approval. Media not istalled and plant is not operational at this time. Working with system to submit plans and NSF 61 certs for treatment equipment to continue with installation.	AdEdge treatment installed April 2014. Collecting monthly post treatment samples. Current running annual average is at 0.034 mg/L.	No
Inyo LPA-44	1400526	Eastern Sierra College Center - Bishop	100	1	NTNC	YES	1100043	12/15/2010	NO	YES			Yes	No	State community college. Have given them the pre-application information and strongly recommended they apply for funding.	System exceeds uranium, arsenic, iron and fluoride. Arsenic levels fluctuate below and above MCL levels so some quarters are not in violation of RAA. Current running annual average is at 0.009 mg/L. System has not been in violation of arsenic MCL since 3rd quarter 2010.	Because well remediation solution did not work, school is looking at potential to consolidate with a nearby facility currently in planning/construction phase.	No	
Kings LPA-46	1600004	FOUR SEASONS MHP	350	88	COMMUNITY	NO	1100223	3/1/2011	YES	YES		1/10/2008	YES		P84/ PLANNING LOAN	ARSENIC MCL VIOLATION	BOTTLED WATER OFFERED AT COST		
Kings LPA-46	1600010	LACEY COURTS MHP	66	21	COMMUNITY	NO	120036	1/3/2011	YES	YES		4/10/2010			DWSRF/ PLANNING	ARSENIC MCL VIOLATION			
Kings LPA-46	1600014	KIT CARSON ELEMENTARY	510	9	NTNC	YES	1000210	4/19/2010							P84/ PLANNING LOAN	ARSENIC MCL VIOLATION			
Kings LPA-46	1600017	ISLAND UNION SCHOOL	300	7	NTNC	YES	1000208	3/3/2009	YES			3/3/2009			P84/ GRANT TO DRILL NEW WELL	ARSENIC MCL VIOLATION			
Kings LPA-46	1600050	CENTRAL VALLEY MEAT	280	2	NTNC	NO	0900196	8/28/2009				8/28/2009	YES			ARSENIC MCL VIOLATION	BOTTLED WATER PROVIDED		
Kings LPA-46	1600296	OLAM INTERNATIONAL	75	7	NTNC	NO	0900196	8/29/2006				8/30/2006	YES			ARSENIC MCL VIOLATION	BOTTLED WATER PROVIDED		
Kings LPA-46	1600504	HAMBLIN MUTUAL	80	39	COMMUNITY	NO	1100221	3/3/2011	YES			4/24/2007			P84/ PLANNING LOAN	ARSENIC MCL VIOLATION			
Kings LPA-46	1600008	CENTRAL UNION SCHOOL	320	3	NTNC	YES													
Los Angeles LPA-49	1900009	Adams Ranch Mutual	300	173	COMMUNITY	NO		11/28/2012	NO	YES			NO	NO		Well 3 exceeds the arsenic MCL	Quarterly monitoring, public notice		
Los Angeles LPA-49	1900038	Lancaster Park Mobile Home Park	53	21	COMMUNITY	NO		2/27/2008	NO			4/14/2011	NO	NO	Invitation for grant funding issued	Well 1 exceeds the arsenic MCL	Quarterly monitoring, public notice, infrastructure repairs in progress	Currently on SRF PPL but bypassed because no full application submitted	
Los Angeles LPA-49	1900100	Mettler Valley Mutual	200	98	COMMUNITY	NO		3/2/2010	NO			3/15/2011	NO	NO		Well 1 exceeds the arsenic MCL	Quarterly monitoring	Full SRF application submitted. District Office clearance 6/30/2014	
Los Angeles LPA-49	1900305	Challenger Memorial Youth Camp	150	1	NTNC	YES		7/12/2011	NO				NO	NO		Well 1, Well2 and Well 3 exceeds the arsenic MCL	Quarterly monitoring, public notice		
Los Angeles LPA-49	1900520	Smith's Village MHP	75	34	COMMUNITY	NO		1/31/2008	NO			6/21/2011	NO	NO	Prop. 84 preapplication under review	Well 1 exceeds the arsenic MCL	Quarterly monitoring, public notice	Full SRF application submitted for consolidation with LACWWD	
Los Angeles LPA-49	1900785	Mitchell's Avenue MHP	35	24	COMMUNITY	NO		2/7/2008	NO			4/19/2011	NO	NO	Prop. 84 preapplication under review	Well 1 exceeds the arsenic MCL	Quarterly monitoring, public notice	SRF full application submitted for consolidation with LACWWD	
Los Angeles LPA-49	1900961	Winterhaven Mobile Estates	27	20	COMMUNITY	NO		2/27/2009	NO			12/22/2011	NO	NO		Well 1 exceeds the arsenic MCL	Quarterly monitoring, public notice	Currently on SRF PPL but no full application submitted	

All Water Systems with Active Arsenic Violations																			
Madera LPA-50	2000293	MD 46 Ahwahnee Resorts	300	90	COMMUNITY	NO	CC0000798	3/25/2009	YES	YES					Submitting Application for SRF	Arsenic and Uranium MCL Exceedance	None. Just submitted application.	Currently they are blending to reduce arsenic levels with some success. They will need additional planning to address combined uranium and arsenic issues.	
Madera LPA-50	2000506	Sierra Linda	180	89	COMMUNITY	NO	CC0000735	1/9/2009	YES	YES					Prop 84 Planning and feasibility FA issued	Arsenic MCL Exceedance	Consolidation Project/New Well/Treatment		
Madera LPA-50	2000512	East Acres Mutual	250	81	COMMUNITY	NO	CC0000742 and CC0000866	2/4/2009	NO	YES					Prop 84 Planning and Feasibility turned down because they did not want to consolidate. Plan to apply to SRF	Arsenic MCL Exceedance	Evaluating consolidation, new source, treatment.	Public Notification Provided	
Madera LPA-50	2000527	Yosemite Forks Estates	110	99	COMMUNITY	NO	CC0000871	9/4/2009	NO	YES					Plan to submit SRF application beginning 2015	Arsenic MCL Exceedance	Have been informally blending, but are unable to provide blend to all homes.	Added additional storage to help with blending. Issued amended compliance order on 06/10/2014 with new compliance deadline date.	
Madera LPA-50	2000534	Leisure Acres	45	24	COMMUNITY	NO	CC0000865	6/29/2009	NO	YES					SRF Funding	Arsenic MCL Exceedance	Evaluating consolidation/New Source/POU treatment	Income survey complete. Deemed only Disadvantaged	
Madera LPA-50	2000538	Cedar Valley Mutual	137	67	COMMUNITY	NO	CC0000737	3/3/2009	NO	YES					SRF Funding. Working on funding application using Assistance Referral.	Arsenic MCL Exceedance	None. Just submitted application.		
Madera LPA-50	2000550	MD 6 Lake Shore	130	45	COMMUNITY	NO	CC0000383	6/25/2007	YES	YES					Prop 84 Planning and feasibility FA issued	Arsenic MCL Exceedance	New Well Drilled. Consolidation Project/New Well/Treatment. Planning in Progress	Trying to become shovel ready by 06/30/2014. P&S to be submitted.	
Madera LPA-50	2000551	MD 7 Marina View Heights	200	74	COMMUNITY	NO	CC0000385	6/25/2007	YES	YES					Prop 84 Planning and feasibility FA issued	Arsenic MCL Exceedance	New Well Drilled. Consolidation Project/New Well/Treatment		
Madera LPA-50	2000552	MD 24 Teaford Meadows	150	66	COMMUNITY	NO	CC0002239	8/29/2014	NO	YES					SRF App. Received 10/31/2014	Arsenic MCL Exceedance	Preparation of P&S. Consolidation Project/New Well		
Madera LPA-50	2000561	MD 8 North Fork	264	80	COMMUNITY	NO	CC0000739	2/4/2009	YES	YES					Prop 84 Planning and feasibility FA issued	Arsenic MCL Exceedance	New Well Drilled. Consolidation Project/New Well/Treatment. Planning in Progress	Trying to become shovel ready by 06/30/2014. P&S to be submitted.	
Madera LPA-50	2000567	Yosemite High School	796	1	NTNC	YES	CC0000809	4/9/2009	YES	YES					Prop 84 Planning and feasibility FA issued	Arsenic MCL Exceedance	Consolidation Project/New Well/Treatment		
Madera LPA-50	2000619	Cold Spring Granite	43	10	NTNC	NO	CC0000799	3/25/2009	YES	YES						Arsenic MCL Exceedance	In 2009 conceptual plan system was to provide bottled water and research remediation of well exceeding the arsenic MCL	Public Notification Provided. Chenge of Operator. In contact with new operator and he has hired someone to prepare a conceptual plan for obtaining compliance.	
Madera LPA-50	2000737	MD 42 Still Meadows	100	34	COMMUNITY	NO	CC0000619	2/4/2009	YES	YES					SRF Funding Project	Arsenic MCL Exceedance	Preparation of P&S. Consolidation Project with Hillview. Planning in Progress.		
Madera LPA-50	2000785	Valley Teen Ranch	50	4	COMMUNITY	YES	CC0000741	2/6/2009	YES	YES			YES		SRF App. deemed complete 08/6/2014	Arsenic MCL Exceedance	Consolidation Project		
Madera LPA-50	2000866	Agriland Farming	190	3	NTNC	NO	CC0000579	2/4/2009	YES	YES						Arsenic MCL Exceedance	System initially proposed adding an nearby agricultural well for blending. Then they concluded that the well did not exceed arsenic if they stopped using it for irrigation. These plans did not pan out.	Public Notice Provided to Employees. A second compliance order will be issued with new compliance deadline date.	
Madera LPA-50	2000612	North Fork Union School	350	3	NTNC	YES	CC0000869	9/4/2009	YES	YES					SRF Funding	Arsenic MCL Exceedance	Test Well Drilled. Possible Treatment/Consolidation. Planning in Progress		
Mono LPA-56	2600622	Sierra East MHP	50	29	COMMUNITY	NO	1200391	2/3/2012	YES	YES			NO	YES	In process for SRF funding. System is awaiting funding to address arsenic mitigation.	Naturally Occurring	Provide centralized treatment	Need to follow up with DE on status of SRF funding process	
Monterey LPA-57	2700612	Laguna Seca WC	162	57	COMMUNITY	NO	CO-2/2/09	3/31/2009 CC0805362	YES	YES			NO				RAA was under MCL for 1 year, but went back over in 3rd qtr 2014. System is researching treatment systems. Issued Q. PON As. Q. As testing	Waiting to see if nearby system with installed treatment can resolve waste discharge issue	
Monterey LPA-57	2700799	Vista Del Toro WS	87	29	COMMUNITY	NO	CO-2/4/09	3/31/2009	NO	YES			NO		Application submitted for SRF Tier 2 Feasibility Study		Applied for prop funding??? Q. PON As. Q. As testing		
Monterey LPA-57	2701221	Washington School	250	1	NTNC	YES	CO-2/3/09	6/30/2009		YES			YES		Feasibility Study underway thru P84		Currently conducting pilot testing for treatment through state funding process. Q. PON As. Q. As testing		
Monterey LPA-57	2701296	Moro Rd. #9 WS	210	70	COMMUNITY	NO	CO-3/31/09	3/31/2009	YES	YES			NO				Regarding CO: spoke to system representative and the plan is to upgrade blending to comply with MCL. Plan Submitted		
Monterey LPA-57	2701503	Mesa del Toro MWC	90	35	COMMUNITY	YES	CO-8/31/09			YES			NO		Was in SRF, requested bypass		Recently drilled new well, undergoing testing to determine if water meets quality/quantity standards. Q. PON As. Q. As testing		
Monterey LPA-57	2701959	Tierra Vista MWC	57	19	COMMUNITY	NO	CO 4/13/11		YES	YES			NO				PON As, Q. As		
Monterey LPA-57	2702009	Laguna Seca Rec WS	500	1	NTNC	NO	CO-1/22/09	3/31/2009	NO	YES			NO	NO			Proposing new treatment technology. Working with SWRCB for tech. approval. WroLM for supervising ranger regarding plan status. Q. As PON/testing		
Monterey LPA-57	2702030	Cypress Community Church WS	200	4	NTNC	NO	CO-1/28/09	per CO, plan due 4/10/09		YES			YES		Full compliance due 1/10/2010		CO issued, waiting on plan and system on quarterly notification		
Monterey LPA-57	2702050	Church of the Good Shephard WS	50	1	NTNC	NO	CO-2/2/09			YES			YES				NOV ISSUED W/ CC TO CDPH & EPA		
Monterey LPA-57	2702051	Corral de Tierra Estates WS	45	16	COMMUNITY	NO	CO-1/22/09	3/31/2009	YES	YES			NO				CO issued, plan received, letter from cal am on file stating they can receive service		
Monterey LPA-57	2702550	Grange Hall WS	25	1	NTNC	YES	CO-2/4/09			YES							Q. PON As. Monthly As sampling	treatment plant was working, but system removed treatment plant- said too expensive to operate. New compliance order to be issued.	
Riverside LPA-63	3301380	Saint Anthony Trailer Park	300	95	COMMUNITY	NO	1203407	3/3/2010	YES	YES			NO	YES	New owner has applied for funding.	Arsenic MCL violation (running annual average = 19 ppb)	Interim treatment has been installed (POU). New well has been installed. New entitlement will require centralized treatment.	Tier 2 arsenic notifications issued quarterly. Well is sampled for arsenic quarterly.	NO
ALL SYSTEMS																			

All Water Systems with Active Arsenic Violations

																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																</
--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	----

All Water Systems with Active Arsenic Violations																							
San Joaquin LPA-69	3901392	ENVIROPLEX	25	1	NTNC	NO	CC0002468	4/1/2012	YES	YES								System was testing a well for one year to see if blending was an option. Data found blending would not meet standards. Will be submitting a treatment proposal by 9/30/12.	Treatment plant was approved for construction. Installing treatment system at this time 12/2/14. To be completed by 1/31/15.				
San Joaquin LPA-69	3900579	CENTURY MOBILE HOME PARK	50	16	COMMUNITY	NO	CC0000977	8/15/2006	YES	YES			1/31/2015				SRF application submitted 2008	SWRCB working with Eng and Stockton to connect to WS	Stockton to make a connection to WS.				
San Joaquin LPA-69	3901213	AVALOS, SILVIA	30	15	COMMUNITY	NO	CC0001685	8/28/2008	YES	YES							NONE. SRF application submitted 2008 was for nitrate not arsenic. Waiting on Century MHP SRF approval for city connection. This system can make a connection to city water off of new line to Century MHP.		System lacks money. Public Notification	Waiting for Century MHP to be served by city for system to make a connection.			
San Luis Obispo LPA-70	4000512	Bella Vista Mobile Lodge	28	85	COMMUNITY	NO	2009-002	1/16/2009	NO	YES					NO		ON ASSISTANCE REFERRAL LIST I THINK	Currently blends water to reduce overall arsenic levels to below MCL. Cannot secure a permanent source of blending water.	New owners. Revisiting permanent source of blend or consolidation.				
San Luis Obispo LPA-70	4000637	Country Hills Estates	81	27	COMMUNITY	NO	2009-001	1/16/2009	NO						NO	YES (at some homes), most use bottled water	na	System is saving for treatment.	All wells in area have arsenic, system reluctant to invest in new sources, the want to do treatment, I'm encouraging them to revisit consolidation.				
San Luis Obispo LPA-70	4000774	Pleasant Valley Elementary	150	1	NTNC	YES	2009-003	1/16/2009	NO						YES		WORKING ON PLANNING LOAN I THINK (check with Jeff Densmore)	System is exploring a new source.	First choice new source, second is treatment				
Stanislaus LPA-80	5000033	Coble's Corner	50	20	COMMUNITY	NO	DER-10CO-003	3/19/2010	NO	YES				9/30/2014	NO	NO		Funding issues for RTC. Funding of LWS for consolidation of this system is being explored.	Consolidation in city of Hughson water supply.				
Stanislaus LPA-80	5000051	Mobile Plaza Park	125	50	COMMUNITY	NO	DER-10CO-008	9/21/2010	NO	YES				3/31/2015	NO	NO		Funding issues for RTC. Funding of LWS for consolidation of this system is being explored.	Consolidation into city of Keyes water supply.				
Stanislaus LPA-80	5000077	Ceres West MHP	161	46	COMMUNITY	NO	DER-13CO-001	3/6/2013	NO	YES				3/31/2016	NO	NO		Funding issues for RTC.					
Stanislaus LPA-80	5000080	Country Western MHP	120	60	COMMUNITY	NO	DER-10CO-004	3/19/2010	YES	YES				9/30/2014	NO	NO	Issued a funding agreement, but turned down offer.		Arsenic and Mangense treatment facilities.	Plans approved; waiting for completion of construction.			
Stanislaus LPA-80	5000085	Green Run Mobile Estates	100	46	COMMUNITY	NO	DER-10CO-002	3/19/2010	NO	YES				9/30/2014	NO	NO		Funding issues for RTC. Funding of LWS for consolidation of this system is being explored.	Consolidation into city of Keyes water supply.				
Stanislaus LPA-80	5000086	Countryside MH Estates	60	44	COMMUNITY	NO	DER-12CO-001	7/9/2012	NO	YES				3/31/2015	NO	NO		Funding issues for RTC. Funding of LWS for consolidation of this system is being explored.	Consolidation into city of Keyes water supply.				
Stanislaus LPA-80	5000218	Country Villa Apts.	30	23	COMMUNITY	NO	DER-13CO-003	5/2/2013	NO	YES				5/2/2016	NO	NO		Funding issues for RTC. Funding of LWS for consolidation of this system is being explored.	Consolidation in city of Hughson water supply.				
Stanislaus LPA-80	5000273	Gratton School	110	2	NTNC	YES	DER-10CO-001	3/17/2010	YES	YES				9/30/2014			Issued a funding agreement	Test hole for new source indicates supply will not RTC. Developing new source, since existing has bacteriological issues time to time.	New source and possilbe future arsenic treatment.				
Stanislaus LPA-80	5000308	B&H Manufacturing	90	1	NTNC	NO	DER-10CO-009	9/23/2010	NO	YES				3/31/2015	YES	NO		Installation of new source not likely to result in RTC, currently city of Ceres consolidation negotiation has not worked out.					
Stanislaus LPA-80	5000389	Monterey Park Tract CSD	186	50	COMMUNITY	NO	DER-10CO-007	9/21/2010	YES	YES				3/31/2015	YES	NO	Issued a funding agreement		Consolidation into city of Ceres water supply.				
Stanislaus LPA-80	5000465	Duarte Nursery	75	7	NTNC	NO	DER-13CO-009	6/13/2013	YES	YES				6/4/2014				Two domestic wells with As MCL	Technical report for blending and new sources submitted. Report was not approved.				
Stanislaus LPA-80	5000484	United Pallet	45	5	NTNC	NO	DER-13CO-004	3/18/2013	YES	YES				3/18/2016				Consolidation into city of Ceres water supply.					
Stanislaus LPA-80	5000555	Fresh Point (Piranha Produce)	26	2	NTNC	NO	DER-13CO-005	3/18/2013	YES	YES				3/18/2016					Arsenic treatment facility.	Treatment plant is installed and operational. RTC will be issued once RAA is below 0.010 mg/L.			
Stanislaus LPA-80	5000570	Valley Peterbilt	25	2	NTNC	NO	DER-10CO-006	9/21/2010	NO	YES				3/31/2015	YES	NO		Installation of new source not likely to result in RTC, currently city of Turlock consolidation not feasible at this time.					
Tehama LPA-82	5201137	Millstream MHP	118	53	COMMUNITY	NO	cc0000005	1/28/2009	NO	YES	cc0000005	10/3/2011		2015	NO	NO		MCL EXCEEDENCE	WAS GOING TO CONSOLIDATE				
Tehama LPA-82	5200550	Orchard MHP	100	43	COMMUNITY	NO	cc0000006	1/28/2009	YES	YES				2015	NO	NO	IN THE WORKS	MCL EXCEEDENCE	PLAN TO CONSOLIDATE				
Yolo LPA-87	5700652	Yolo Filers Club	410	3	NTNC	NO	1401084	9/24/2014	NO	YES					NO	NO		Running annual average of 11.25 ppb	Currently comparing proposals from two different companies for treatment.			NO	
Yolo LPA-87	5700778	Yolo County Central Landfill	40	3	NTNC	NO	1401051	7/14/2014	YES					1/1/2016	NO	YES		Running annual average of 11.4 ppb for raw source water samples	Design and installation of centralized treatment.	Temporary proposal approved for reverse osmosis POU treatment			
														8/15/2015									

All Water Systems with Active Arsenic Violations																						
Yuba LPA-88	5800004	MARIANI PACKING CO	30-75	5	NTNC	NO		6/30/2009	YES	YES				Yes	Yes		HIGH ARSENIC & RADIOLOGICAL CONTAMINANT LEVELS	SYSTEM INSTALLED POE & CRANMER ENGINEERING IS GETTING BIDS FOR INSTALLATION OF A TREATMENT UNIT.	THIS PACKING PLANT HAS SEEN DECLINING EMPLOYEE #S FOR THE PAST SEVERAL YEARS & HAS CONTACTED YCEH TO INACTIVATE THEIR SYSTEM. IN THE MEAN TIME, THEY ARE STILL MOVING FORWARD WITH RESEARCHING TREATMENT FOR BOTH ARSENIC & RADIOS.			
Yuba LPA-88	5800878	GEORGE AVE APARTMENTS	35	10	COMMUNITY	NO		6/30/2009	YES			11/23/2010					HIGH ARSENIC LEVEL	SOLUTIONS WERE RESEARCHED, HOWEVER, FUNDING IS UNAVAILABLE. OWNER WILL REMOVE HOMES AND BRING THE POPULATION UNDER 25 BEFORE 12/31/2011.				

Water Systems with Arsenic Violations Returned to Compliance

DISTRICT or COUNTY NAME- DISTRICT NUMBER	SYSTEM NUMBER	SYSTEM NAME	POPULATION	SERVICE CONNECTIONS	PWS CLASSIFICATION	IS THE PWS A SCHOOL OR DAYCARE THAT SERVES PEOPLE <18YRS.?	1ST ENF ACTION NO. ISSUED (Use the State Assign ID # in SDWIS)	1ST ENF ACTION ISSUE DATE (Status Date in SDWIS)	COMPLIANCE PLAN SUBMITTED? (Yes/No)	WAS A COMPLIANCE ORDER ISSUED? (Meets EPA's Formal Action Criteria)	2ND ENF ACTION NO. ISSUED (Use the State Assign ID # in SDWIS)	2ND ENF ACTION ISSUE DATE (Status Date in SDWIS)	DATE PWS MUST BE IN COMPLIANCE BY	BOTTLED WATER OR HAULED WATER PROVIDED (Yes/No)	POU/POE PROVIDED (Yes/No)	FUNDING STATUS (If Applicable)	PROBLEM DESCRIPTION	PROPOSED SOLUTION	NOTES	RTC?	RTC DATE	RTC BASIS
Butte LPA-34	0400049	Butte Creek MHP	100	33	COMMUNITY	NO	0900104	9/13/2013	NO	YES						Water system is ordered to submit application during the next open enrollment period. Has not applied for funding yet.	Arsenic above MCL for Well #6.	Quarterly monitoring of Arsenic		YES	4/10/2014	RAA < MCL - Natural Causes
Butte LPA-34	0400058	Rancho Villa Mobile Acres	32	22	COMMUNITY	NO	0900018	3/6/2009	YES								Arsenic over the MCL	SRF funds have been approved for incorporation with the City of Gridley's water system.	Connection to Gridley is complete. Need final touches to complete project.	YES	3/18/2014	PWS Inactive - No longer a PWS
Fresno-23	1000472	PG&E Helms Support Facility	36	20	COMMUNITY	NO	0923001	5/1/2009		YES						Will self-fund a project	As exceedance based on 2 quarterly samples in sole source	Treatment installed		YES	3/1/2014	RAA < MCL - Treatment Installed
Fresno-23	1010030	Tranquillity Irrigation District	820	326	COMMUNITY	NO	EPA NO. PWS-AO-2008-6019	9/25/2008	YES	YES						P84 planning study completed. P84 construction project underway.	2 of 2 wells exceed	Purchased 2 wells that comply with As MCL.	Wells purchased and online. System eligible to RTC based on 4QRAA. USEPA Administrative Order, so DDW cannot RTC via SDWIS.	YES	11/1/2014	Source(s) Abandoned
Inyo LPA-44	1400004	Charles Brown Water Company	330	100	COMMUNITY	YES	None	None	NO	NO						Privately owned Comm system.	Arsenic MCL exceedence due to untreated water used to fill tank. System served untreated water for less than a week. May take a while for RAA to go below MCL so can RTC.	Tank slowly refilled with treated water and all sampling since the event have been below MCL. It will take several quarters for RAA to drop below MCL.		YES	4/1/2012	RAA < MCL - Treatment Installed
Inyo LPA-44	1400528	Crystal Geyser Bottling Plant	100	2	NTNC	NO	1100063	12/29/2010	YES	YES						Privately owned NTNC.	Both wells exceed arsenic. Used POU until treatment options were researched. AdEdge treatment units have been installed. Waiting for monitoring data for start-up.	Treatment installed and monitoring is in progress. May take several quarters for system to RTC because of RAA.		YES	1/1/2012	RAA < MCL - Treatment Installed
Kings LPA-46	1600011	PIONEER ELEMENTARY	750	6	NTNC	YES						12/18/1998				ARRA/ CONSTRUCTION FA	ARSENIC MCL VIOLATION	NEW WELL TO BE DRILLED 2011		YES	6/20/2014	RAA < MCL - Well Modified
Kings LPA-46	1600605	BAKER COMMODITIES	47	2	NTNC	NO						1/10/2008		YES			ARSENIC MCL VIOLATION	BOTTLED WATER PROVIDED				
Kings LPA-46	1600601	KWRA	53	3	NTNC	NO	1200239	5/1/2012		YES		1/11/2008		YES			ARSENIC MCL VIOLATION	BOTTLED WATER PROVIDED		YES	10/1/2014	Source(s) Reclassification
Lassen-02	1805004	High Desert Prison	10,950	2,274	COMMUNITY		USEPA issued CO	USEPA issued CO		YES							3 wells exceeded	Central treatment installed and operating as of May 2008.		YES	1/6/2008	RAA < MCL - Treatment Installed
Lassen-02	3100033	Tahoma Meadows Mutual Water Company	120	43	COMMUNITY	NO	CC0000394	8/24/2011	NO	YES							sole source is a well which exceeds the As MCL. The running annual average from October 2010 through July 2011 is 19.2 ug/L. The PS code is 3100033-001.	The well has been reconstructed in an attempt to meet the As MCL. However, this was not effective. The water system has been pursuing consolidation with another nearby public water system, but has not yet been successful.		YES	12/5/2013	PWS Inactive due to Consolidation
Lassen-02	3210003	City of Portola	2500	1083	COMMUNITY	NO	0902006	2/26/2009		YES						No SRF application	Corp Yard Well exceeds MCL	This well will be converted to emergency standby source.		YES	10/24/2012	Source(s) Reclassification
Lassen-02	4510005	City of Redding	85703	26080	COMMUNITY	NO	0902008	4/20/2009		YES						Project to provide treatment on SRF-Project Priority List in Category L. (Needs to be changed to Catenorv G.)	Enterprise Well 13 exceeds MCL	The City has not used Well 13 since July 2008 and is considering submitting a request to change the well to emergency standby source status.		YES	10/16/2012	Source(s) Reclassification
Los Angeles LPA-49	1900756	Warm Springs Rehabilitation Center	200	1	NTNC	NO											Wells 1, 2, & 3 exceeds that arsenic MCL	camp currently closed as a result of operational problems; all users moved to Acton Rehabilitation Center		YES	?	PWS Inactive due to Closing
Los Angeles LPA-49	1909007	Our Lady of Fatima	300	1	NTNC	NO											Well 1 exceeds the arsenic MCL			YES	12/1/2009	Source(s) Reclassification
Madera LPA-50	2000502	Bass Lake Height	250	102	COMMUNITY	NO	CC0000736	1/5/2009	YES	YES						Invited to apply for Prop 84		Arsenic treatment installed. Arsenic sample taken post treatment on 7/12/2011 is ND. Treament has been online since 6/17/2011.		YES	6/22/2011	RAA < MCL - Treatment Installed
Madera LPA-50	2000688	ECCO	100	43	COMMUNITY	NO	CC0000870	10/1/2009	YES	YES							Arsenic MCL Exceedance	Blending Successfully. Operation and Maintenance Plan Reviewed and Approved.	Only seasonally use the well with Arsenic MCL exceedance. They blend during this time.	YES	12/5/2014	RAA < MCL - Blending

Water Systems with Arsenic Violations Returned to Compliance

Madera LPA-50	2000524	Sky Acres Mutual	90	50	COMMUNITY	NO	CC0001312	2/11/2011	NO	NO								Arsenic running annual average since 1st quarter 2012 have been below the MCL. System has returned to compliance.	YES	6/20/2014	Running Annual Average for Arsenic has been below MCL for 2 years.
Mendocino-03	2310011	Laytonville CWD	1,301	370	COMMUNITY		USEPA issued CO	USEPA issued CO		YES					Preapplication submitted	Source water exceeds As MCL; Filtronics As treatment installed; operational problems being resolved by system.	Treatment installed and being commissioned in place.		YES	4/1/2009	RAA < MCL - Treatment Installed
Merced-11	2400075	El Nido Elementary School	310	1	NTNC	YES			YES	YES					SRF & School Bond Law funding completed in 2009	Problem solved	Coagulation/filtration	Treatment on-line in 2008	YES	1/1/2008	RAA < MCL - Treatment Installed
Merced-11	2400147	Clausen Meat Packing	30	1	NTNC	NO										Arsenic is above MCL in the only active well.	System is non-communicative. LPA has been focusing on bacteriological monitoring violations.		YES	3/25/1993	PWS Inactive - No longer a PWS
Merced-11	2400170	Hilmar Cheese	712	1	NTNC	NO			YES	YES						Problem solved	Coagulation/filtration	Primary well arsenic level jumped from 4 to 19 ug/L in 11/2008. Treatment on-line 12/23/2010	YES	12/23/2010	RAA < MCL - Treatment Installed
Merced-11	2400172	Sandy Mush Detention Center	800	157	COMMUNITY	YES	NOV	9/24/2007	YES	YES						Problem solved	Adsorptive media (GFH)	Treatment on-line 5/7/2008	YES	5/7/2008	RAA < MCL - Treatment Installed
Mono LPA-56	2600700	Sierra Business Park	35	37	NTNC	NO										Naturally Occurring	Point of Entry Treatment		YES	12/17/2010	PWS Inactive - No longer a PWS
Monterey LPA-57	2702439	Woodland Heights MWC	57	19	COMMUNITY	NO	CO issued 1/29/09	proof of public notification for 1st Qtr, 2009 due to EHD by 4/10/09	YES			Implementation plan for development of an acceptable permanent source by 4/30/09				Upon approval by EHD, the plan shall be implemented and water served shall meet standards by 1/31/2010	Fe/Mn plant was modified to include As. Treatment. Q. PON As. Q. As testing		YES	11/10/2014	RAA < MCL - Treatment Installed
Monterey LPA-57	2700552	Echo Valley School WS	503	1	NTNC	YES	CO 10/001 2/16/2010										Q. PON Bottled Water & As. As testing distribution 2x/mo & 1x/mo source	Fe/Mn treatment working for As, but haven't been able to obtain waste discharge permit	Yes	3/29/2013	RAA < MCL - Treatment Installed
Monterey LPA-57	2701227	San Benancio School	200	2	NTNC	YES	CO-2/4/09	3/31/2009				1/31/2010			P84-In construction to consolidate with CalAm Ambler Park system		NOV issued w/ cc to CDPH and EPA		YES	10/1/2012	PWS Inactive due to Consolidation
Monterey LPA-57	2701670	Langley Valle Pacifico WS	81	27	COMMUNITY	YES	CO-1/27/09	application complete by 1-5-2009 CO plan due March 31, 2009	YES			1/31/2010					Invited to apply to SRF-planning to drill well, plan is to wait for granite ridge project and funding. Q.PON As.		YES	6/13/2013	RAA < MCL - Treatment Installed
Monterey LPA-57	2702003	Vierra Meadows MWC	75	25	COMMUNITY	NO	CO-1/29/09	proof of public notification for 1st Qtr, 2009 due to EHD by 4/10/09		YES	Implementation plan for development of an acceptable permanent source by 4/30/09	Y-plan submitted		NO			NOV issued w/ cc to CDPH and EPA; system applied for funding; 2/23/09- Russ Hatch indicated that the system plans to go with an arsenic removal plant; also he said he is aware of the "shovel ready" funding application deadline and will apply; system remains on quarterly public notification; 2/25/10- system submitted application to State for conversion of SRF application for construction funds to planning funds		yes	10/10/2014	RAA < MCL - Natural Causes
Monterey LPA-57	2702370	SPCA	50	8	NTNC	NO	CO 2/2/09										PON As, Q. As		YES	1/1/2013	RAA < MCL - Treatment Installed
Monterey-05	2710021	Cal Am Water Company-Toro	1296	405	COMMUNITY		SEE NOTES	SEE NOTES		NO						Wells 1 & 2 exceed MCL	PN. Arsenic removal treatment installed & permit being processed.	System was in receivership due to federal Court Order. CalAm took over system in 2008 and immediately started to address arsenic issue. Plant is constructed and permit being processed. No enforcement issued as long as CalAm continues to work towards compliance.	YES	9/30/2010	RAA < MCL - Natural Causes

Water Systems with Arsenic Violations Returned to Compliance

Monterey-05	3500565	Fairview Child Development Center	70	2	NTNC	YES	0905033	5/27/2009	NO	YES							Well 1		Existing Fe/Mn treatment is removing arsenic. While 3 monthly samples have exceeded MCL, RAA has been below MCL for last 2.5 years. System has submitted an application to have the plant permitted for arsenic removal.	YES	6/30/2012	RAA < MCL - Treatment Installed
Monterey-05	4410016	Forest Lakes MWC	1,145	327	COMMUNITY		0905011	4/23/2009		YES						Applied for SRF for source capacity issues	Wells 08A	PN & qtrly monitoring.	YES	9/23/2009	Source(s) Abandoned	
Monterey-05	3500570	B & R Farms	25	14	NTNC	NO	05-05-14R-002	5/30/2014	NO	YES							Arsenic RAA=0.013 ug/L at end of 1sr quarter 2014	Action plan due 7/31/2014. On quarterly PN.				
Monterey-05	3500823	Best Road MWC	133	48	COMMUNITY	NO	No ENF was issued due to system changing source to Standby.										Well 01 has had arsenic over MCL	System is not using Well 01, but does not want to change to standby status. We have been patient, but will issue CO in Nov. 2010.	YES	11/15/2010	Source(s) Reclassification	
Napa LPA-58	2800648	Wine Country Inn	25	1	NTNC	NO	1258001 (SIA)	5/24/2011	NO										YES	3/8/2012	RAA < MCL - Treatment Installed	
Riverside LPA-63	3301755	Sunbird Mobile Home Park	258	86	COMMUNITY	NO	1203410	1/29/2009	Yes	YES					Safe Drinking Water State Revolving Fund Project NO 3301755-001. Final plans and specifications for consolidation planning project approved.	Arsenic MCL violation (running annual average = 17 ppb)	Interim treatment has been installed. Consolidation with Coachella Valley Water District Pending. CDPH has reviewed and approved plans, specifications, notice of exemption and agreement documents.	Interim treatment station is providing water that meets arsenic MCL. Consolidation with CVWD pending.	YES	8/6/2012	PWS Inactive due to Consolidation	
Riverside LPA-63	3303048	Manuela Garcia Mobile Home Park	30	15	COMMUNITY	NO	Citation and Compliance Order (1163193)	1/29/2009	Yes	YES							Arsenic MCL violation (running annual average = 11 ppb)	Tier 2 arsenic notifications issued. Owner has approved plans to downsize park and reclassify as a State Small with POU treatment. Constuction of new park in progress	YES	1/5/2012	PWS Reclassified to Transient/State Small	
Sacramento LPA-64	3400169	SPINDRIFT MARINA	100	50	COMMUNITY	NO	1200575	4/12/2012	YES	YES					Universal Pre-Application submitted.	Exceeding the Arsenic MCL	An engineer has evaluated the existing treatment system and made corrections. Futher compliance will be determined.		YES	3/31/2013	RAA < MCL - Treatment Installed	
Sacramento LPA-64	3400248	FRANKLIN ELEMENTARY	246	2	NTNC	YES	0800344	12/04/2009	YES	YES							MCL exceedance well 1	Applied for funding; constructing a treatment plant; provide bottled water for drinking and post public notification. Construction plans have approved for treatment. Construction is currently underway.	YES	12/4/2012	RAA < MCL - Treatment Installed	
Sacramento-09	5710011	Wild Wings CSA	1,187	346	COMMUNITY		0909004	7/30/2009		YES					PN and WS submitted and permit to change well status to standby.	1 well with As>MCL			YES	9/30/2009	Source Reclassification	
Sacramento-09	3410011	City of Galt	22982	7203	COMMUNITY		0909020	1/28/2009	YES	YES		7/1/2010					5 wells exceed Arsenic MCL	PN and AS treatment at 3 GWTP's	YES	1/11/2012	RAA < MCL - Treatment Installed	
San Bernardino LPA-63	3600262	Snowcrest Heights	500	121	COMMUNITY	NO	0201363	11/19/2009	No	YES	#0201928	5/10/2010	12/31/2010		N/A	2 sources exceed As MCL	Tier 2 notifications		YES	12/31/2010	Source(s) Abandoned	
San Bernardino LPA-66	3600192	PG & E Pipeline Operation	30	1	NTNC	NO	WV0000121	7/31/2012	YES	YES	CC0000051	10/4/2012	12/31/2013	YES	NO		Source water exceeds arsenic MCL	Blending	YES	12/19/2012	RAA < MCL - Blending	
San Bernardino-13	3610112	Helendale CSD	8646	2610	COMMUNITY		0913039	2/13/2009		YES								PN and quarterly monitoring required. Looking into	YES	4/1/2012	Drilled a new well	
San Bernardino-13	3610854	Searles Valley Minerals	2100	1386	COMMUNITY	NO	0913016	2/13/2009		YES							Well 4 (003) and Well 361W (001)	PN and quarterly monitoring required. Considering	YES	4/1/2013	RAA < MCL - Treatment Installed	
San Diego LPA-67	3701010	Warner Unified School District	250	15	NTNC	YES									The system is currently seeking SRF Funds. na	Arsenic MCL exceedance at well #3.	Public notification. On going quarterly sampling at well #3.					
San Joaquin LPA-69	3900603	LEISURE MANOR	100	42	COMMUNITY	NO	CC0001758	03/11/200	YES	YES								OX connected to Cal Water Service 6/09	YES	6/1/2009	PWS Inactive due to Consolidation	
San Joaquin LPA-69	3900711	SIDHU MOBILE PARK WATER SYSTEM	75	23	COMMUNITY	NO	CC0001697	5/26/2008	YES						SRF application submitted 2008		foreclosed on, new owner takes over in 10/10. Public Notification. Conneced to city water-OX	OX - Connected to city water 12/11	YES	12/1/2011	PWS Inactive due to Consolidation	
San Joaquin LPA-69	3900712	MUSD-FRENCH CAMP SCHOOL	650	1	NTNC	YES	CC0001694	4/17/2008	YES						SRF application submitted 2008		System is connected to city of Stockton in 6/11. Did Pub Notification & provided bottle water.	OX- Connected to city water 6/11	YES	7/20/2011	PWS Inactive due to Consolidation	
San Joaquin LPA-69	3900732	V&P TRAILER COURT WS	35	15	COMMUNITY	NO	CC0001691	10/21/2007	YES	YES						System needs to wait to see how much land CalTrans will take when Hwy 99 clover leaf is designed.	To submit a engineered plan to LPA by 9/30/2012.	Cal Trans work completed in 2014.	yes	7/21/2014	RAA < MCL - Natural Causes	
San Joaquin LPA-69	3900810	JR SIMPLOT CO	300	1	NTNC	NO	CC0001681	8/28/2008	YES						NA		Approved engineered treatment plant installed in 6/11. Did Pub Notification & provided bottled water.	OX- Treatment plant installed in 2011	YES	6/1/2011	RAA < MCL - Treatment Installed	

Water Systems with Arsenic Violations Returned to Compliance

Joaquin LPA-69	3900815	DELICATO VINEYARDS	25	1	NTNC	NO	CC0001698	6/25/2008	YES	YES						NA		System investigating drilling a new source. Doing PUB Notification. 9/4/2012: Drilled test well and tested for one year for constructing a new well. Will be submitting a compliance plan to LPA by 9/30/12.		yes	8/14/2014	RAA < MCL - Well Modified
San Joaquin LPA-69	3900818	LATHROP SANDS TRAILER COURT	105	35	COMMUNITY	NO	CC0001683	8/28/2008	YES	YES						NA		OX System connected to city of Lathrop water 10/09		YES	10/1/2009	PWS Inactive due to Consolidation
San Joaquin LPA-69	3901032	LODI USD-TURNER SCHOOL	200	2	NTNC	YES	CC0001684	8/28/2008	YES	YES						SRF application submitted 2008		School closed 6/30/09.		YES	6/30/2009	PWS Inactive due to Closing
San Joaquin LPA-69	3901390	FRANK ALEGRE TRUCKING	25	1	NTNC	NO	CC0002463	4/1/2012	YES	YES							Exceeds Arsenic MCL	Treatment plant was installed and operating under pilot program.	yes	2/14/2014	RAA < MCL - Treatment Installed	
San Joaquin-10	3901204	DIAMOND PET FOOD	35	2	NTNC	NO	CC0001767	8/28/2008	YES	YES						NA		OX System connected to city of Lathrop water 7/09		YES	7/1/2009	PWS Inactive due to Consolidation
Santa Barbara-06	5603118	Ventura Farms	45	20	NTNC	NO	0906004	12/16/2008		YES							Well K1	Requiring PN and quarterly monitoring. Providing		YES	6/30/2010	RAA < MCL - Natural Causes
Santa Clara-17	4100004	City of Gridley	6,403	2,077	COMMUNITY		USEPA issued CO	USEPA issued CO		YES							One well (Fairwell Well) exceeded MCL and was placed in emergency standby mode.	Wrote violation letter. Response by system was to take well out of service and place in standby status.		YES	12/31/2007	Source(s) Reclassification
Sonoma-18	4901061	Sonoma Warehousing	200	2	NTNC		USEPA issued CO	USEPA issued CO		YES						No SRF application	Only well arsenic RAA = 26 µg/L.	System successfully piloted adsorption media treatment.		YES	12/31/2008	RAA < MCL - Treatment Installed
Sonoma-18	4901136	Wilson Elementary School	200	2	NTNC	YES	1018007	5/28/2009		YES						Offered Bondlaw, SRF, Prop 84, and ARRA funds.	Only well arsenic RAA = 21 µg/L.	Consolidating with the City of Petaluma.		YES	12/31/2009	PWS Inactive due to Consolidation
Sonoma-18	4901236	Vino Farms Preston Ranch	60	8	NTNC		0918004	2/25/2009		YES						No SRF application	Both wells exceed arsenic MCL. Standby well arsenic 140 µg/L. Well 2 arsenic 170 µg/L.	Sources off line. Hauling water.		YES	2/2/2010	Drilled a new well
Sonoma-18	4901247	Carneros Warehousing	50	2	NTNC					NO						No SRF application	Only well arsenic RAA 17µg/L .	System currently piloting and result indicate successful.		YES	2/2/2010	RAA < MCL - Treatment Installed
Sonoma-18	4901294	Wine Country Ind Park - Bldgs A&B	30	2	NTNC		USEPA issued CO	USEPA issued CO		YES						No SRF application	Only well arsenic RAA = 12 µg/L.	System is proposing to install treatment.		YES	3/31/2009	RAA < MCL - Natural Causes
Sonoma-18	4910011	Sebastopol, City of	7,750	2,885	COMMUNITY		0918006	2/10/2009		YES						SRF preapplication	One well arsenic RAA = 16 µg/L. System has 3 additional sources.	Attempting to block off arsenic-laden strata.		YES	12/31/2009	RAA < MCL - Treatment Installed
Sonoma-18	4900716	Cinnabar Elementary School	228	1	NTNC	YES	918004	6/14/2013	NO	YES			12/31/2014	NO	NO	Not applied	Arsenic MCL	hope RAA stays below MCL	one sample 3/13/2013 put As RAA over MCL but all results since have been less than MCL	YES	3/11/2014	RAA < MCL - Natural Causes
Sonoma-18	4900723	Shamrock Mobile Home Park	188	127	COMMUNITY	NO	0918007	4/10/2009	NO	YES						No SRF application	Only well arsenic RAA = 26 µg/L.		Letter to System re-quiring plan and time schedule.	YES	4/15/2013	RAA < MCL - Treatment Installed
Sonoma-18	4900845	Rancho De Sonoma Mobile Home Park	130	98	COMMUNITY		EPA NO. PWS-AO-2008-6014	7/31/2008	YES	YES			6/30/2010			Universal preapplication. Need income survey to demonstrate disadvantaged community status.	Only well arsenic RAA = 15 µg/L.	System has applied for Prop 84 funds to consolidate		YES	4/6/2012	PWS Inactive due to Consolidation
Sonoma-18	4900904	J Vineyards & Winery	40	1	NTNC		EPA NO. PWS-AO-2008-6013	6/3/2008	YES	YES			6/30/2010			No application for funding as no project is required.	Only well arsenic RAA 39 µg/L.	System proposing to install adsorption media treat	In compliance, permit pending	YES	9/28/2010	RAA < MCL - Treatment Installed
Sonoma-18	4901218	Groskopf Warehouse & Logistics	60	6	NTNC	NO	EPA NO. PWS-AO-2008-6015 & NOV 0918016	7/31/2008 & 06/2/2009	NO	YES			9/30/2010			No application for funding as no project is required.	Only well arsenic RAA 13 µg/L.	System proposing to install adsorption media treat	Ran pilot, exhausted media in 1 week, choosing new treatment system.	YES	8/17/2012	RAA < MCL - Treatment Installed
Sonoma-18	4901225	Rental Place	45	2	NTNC	NO	EPA NO. PWS-AO-2008-6017 & NOV 0918008	9/2/2008 & 6/2/2009	NO	YES			3/31/2010			No application for funding as no project is required.	Only well arsenic RAA 42 µg/L.	System proposing to install adsorption media treat	Running pilot, on track to be in compliance by 12/31/2010.	YES	1/4/2013	RAA < MCL - Treatment Installed
Sonoma-18	4901323	Fulton Processors, Inc.	100	1	NTNC		0918004	12/31/2008	YES	YES			3/31/2010			No application for funding as no project is required.	Only well arsenic RAA 15 µg/L.	System has called to discuss treatment options. N	Has requested time extension which will be issued soon	YES	7/12/2010	PWS Inactive due to Closing
Stanislaus LPA-80	5000195	Swanson Farms	25	1	NTNC	NO	DER-13CO-002	3/11/2013	NO	YES										YES	4/23/2014	PWS Inactive - No longer a PWS
Stockton-10	3910005	City of Manteca	66451	18372	COMMUNITY	NO	0910018	1/5/2009		YES						SRF pre-app filed	Wells 12-16, 19, 20, 22-25 exceed As MCL with As at 11 to 16 ug/L.	Treatment installed on 16, 22, 23 operational for		YES	12/31/2013	RAA < MCL - Blending
Stockton-10	3910015	City of Lathrop	12427	3675	COMMUNITY	NO	0910027	12/26/2008		YES						Proceeding with Application for SRF Funding	All 4 wells exceed As MCL with As 14 -21 ug/L.	Preliminary central treatment designed.		YES	5/30/2014	RAA < MCL - Treatment Installed
Tehachapi-19	1500190	Edmundson Acres Water System	550	84	COMMUNITY		0919023	1/23/2009		YES						ARRA project completed in 06/2010	One well with arsenic and nitrate violation	Consolidated with Arvin CSD in 06/2010 using ARRA funds	System consolidated with Arvin CSD already.	YES	6/30/2010	PWS Inactive due to Consolidation
Tehachapi-19	1502221	Pond School Water System	250	2	NTNC	YES	0919011	1/23/2009		YES										YES	12/31/2011	RAA < MCL - Treatment Installed
Tehachapi-19	1502465	Panama Road Property Association	50	16	COMMUNITY		0819007	4/18/2008		NO										YES	12/30/2008	RAA < MCL - Natural Causes
Tehachapi-19	1502595	National Cement Company Lebec Plant Water System	120	1	NTNC	NO	1019011	9/13/2012											NEW VIOLATION ADDED TO LIST ON 07/29/10	YES	7/23/2013	RAA < MCL - Treatment Installed


Water Systems with Arsenic Violations Returned to Compliance

Tehachapi-19	1510018	Rosamond Community Services District	10,633	4,398	COMMUNITY		0919020	1/23/2009		YES							Well 06 and Well 07 are in violation of the arsenic MCL, RAA of both wells in 0.014 mg/L	Drilling new wells and proposal to provide arsenic.		YES	1/30/2009	Source(s) Abandoned
Tehachapi-19	1500600	J. G. Boswell Company Water System	50	4	NTNC	NO	0919021	1/23/2009		YES							Well 01 is in violation of the arsenic MCL, RAA 0.028 mg/L	Proposal to provide POE arsenic removal treatment		YES	12/31/2011	RAA < MCL - Treatment Installed
Tehachapi-19	1502771	Kern Oil and Refining Company	99	18	NTNC	NO	0919016	1/23/2009		YES							Well 02 is in violation of the arsenic MCL, RAA 0.013 mg/L	Considering arsenic removal treatment.		YES	10/29/2013	RAA < MCL - Treatment Installed
Tehachapi-19	1503380	J G Boswell Tomato Company, LLC	125	3	NTNC		0919008	1/23/2009		YES							Well 01 is in violation of the arsenic MCL, RAA 0.027mg/L. Well 02 on quarterly monitoring & has not yet failed the MCL (avg. samples = 0.014 mg/L.)	Will need to provide arsenic removal treatment.		YES	12/31/2011	RAA < MCL - Treatment Installed
Tehachapi-19	1510017	Indian Wells Valley Water District	30000	11643	COMMUNITY	NO	0919027	1/23/2009		YES							Well 13 and Well 09A are in violation of the arsenic MCL, RAA 0.022 to 0.032 mg/L	Proposal already submitted to provide arsenic removal		YES	1/1/2013	RAA < MCL - Treatment Installed
Tehachapi-19	1510028	Mill Potrero Mutual Water Company	1,700	2,287	COMMUNITY	YES	1119011	12/14/2010	NO								Arsenic MCL Violation of Well 7	Plan to develop a arsenic blending plan with other low arsenic wells.		YES	1/1/2013	RAA < MCL - Blending
Valley-21	2910011	PlaVada Community Association	400	252	COMMUNITY	NO	EPA NO. PWS-AO-2008-6024	9/30/2008	YES	YES			12/31/2010		System did not update its SRF application.	System has 2 wells and both produce water that exceeds 10 ug/l As.	Arsenic treatment plant installed and operational.	Under a federal EPA compliance order.	YES	1/1/2012	RAA < MCL - Treatment Installed	
Valley-21	5100141	Meridian Elementary School	93	1	NTNC	YES	USEPA issued CO	USEPA issued CO		YES					No SRF application	Treatment added to well source. Adsorptive media.	No decisions presented to CDPH.		YES	7/9/2009	RAA < MCL - Treatment Installed	
Valley-21	5110001	City of Live Oak	7,475	2,186	COMMUNITY		USEPA issued CO	USEPA issued CO		YES					Prop 40 grant given, have SRF application to treat remaining untreated well.	All 5 wells exceed MCL.	Not permitted at this time due to marginal results. Permit was issued 6/23/2009.		YES	12/31/2009	RAA < MCL - Treatment Installed	
Valley-21	5110003	Yuba City GW Region 2-3	10,200	3,014	COMMUNITY		Not Issued			YES					SRF Application submitted.			SRF project should be completed by the end of 2010.	YES	10/7/2010	PWS Inactive due to Consolidation	
Valley-21	0600013	Princeton Water District	356	118	COMMUNITY	NO	0921006	8/18/2009	YES	YES			12/31/2010		Local funds	Well#1	Modifying non-complying well	Well work completed. Initial tests show success.	YES	8/21/2012	RAA < MCL - Well Modified	
Valley-21	5100139	Franklin Elementary School	468	1	NTNC	YES	1121007	9/1/2010	NO	YES					P84 consolidation project to Yuba City completed	RAA of well = 0.0135 mg/L			YES	Nov-14	PWS Inactive - No longer a PWS	
Valley-21	5100140	Marcum Illinois Elementary School	200	1	NTNC	YES	0921004	1/5/2009	YES	YES			Second Quarter 2010		No SRF application	Well water exceeds MCL, only one active well	12 POUs have been installed as interim measure. Drilled new well.	Trying to solve with local funds.	YES	7/1/2010	Drilled a new well	
Valley-21	5100145	Winship Elementary School	50	1	NTNC	YES	0921009	1/5/2009	NO	YES			Not Specified Goal of 12/31/10		Submitted Universal Application	Well water exceeds MCL, only one active well	No decisions presented to DPH. Providing vended w	System does not meet the definition of a PWS anymore; <25 people.	YES	11/30/2010	PWS Inactive due to Closing	
Valley-21	5100153	Holt of California	100	1	NTNC	NO	0921004	1/2/2009	NO	YES			Not Specified Goal of 12/31/10		No SRF application	Well water exceeds MCL, only one active well	No decisions presented to DPH, providing bottled w		YES	1/17/2014	RAA < MCL - Treatment Installed	
Valley-21	5100158	Sunset Moulding	65	1	NTNC		0921004	2/4/2009	NO	YES			Not Specified Goal of 12/31/10		No SRF application	Well water will exceed MCL next quarter, only one active well	No decision - interim bottled water being provided		YES	7/30/2012	PWS Inactive - No longer a PWS	
Valley-21	5100172	Encinal Elementary School	60	1	NTNC	YES	1121009	10/13/2010	NO	YES					Pre-application has not been submitted, but will during the next open enrollment.	RAA=0.0133 mg/L			YES	1/17/2014	RAA < MCL - Treatment Installed	
Valley-21	5100180	Grace Baptist Church	200	1	NTNC	YES	0921005	1/5/2009	NO	YES					Unable to apply for SRF	Well water exceeds MCL, only one active well	Have installed centralized treatment, but still providing bottled water. Permit amendment needed.	public notification has stoppped	YES	Sep-14	RAA < MCL - Treatment Installed	
Valley-21	5101001	First United Methodist Church	65	1	NTNC		0921022	1/5/2009	NO	YES			Not Specified Goal of 12/31/10		No SRF application	Well water exceeds MCL, only one active well	Bottled water permit. Using vended water.		YES	11/2/2010	PWS Inactive due to Consolidation	
Valley-21	5105008	Valley Farm Transport	25	1	NTNC	NO	0921004	1/5/2009	NO	YES			Not Specified Goal of 12/31/10		No SRF application	Well water exceeds MCL, only one active well	Bottled water permit as temporary measure.		YES	8/23/2012	RAA < MCL - Treatment Installed	
Visalia-12	1510006	East Niles CSD	25500	7406	COMMUNITY		0912010	5/21/2009		YES										YES	12/31/2009	RAA <MCL - Treatment/Blending
Visalia-12	1502622	Gosford Road Water Company	52	15	COMMUNITY	NO	0919010	1/23/2009		YES							Well 01 is in violation of the arsenic MCL, RAA 0.013 mg/L	Too far away from City of Bakersfield for consolidation		YES	12/31/2011	Source(s) Reclassification
Visalia-12	1510019	City of Shafter	15812	4207	COMMUNITY	YES	1112020	2/10/2011		YES							Well 17 exceeded the arsenic RAA MCL.			YES	5/13/2014	RAA < MCL - Well Modified
Visalia-12	1510802	Kern Valley State Prison	6546	2248	COMMUNITY	NO	0912002	12/12/2008							Proposed project - unknown funding source	2 wells exceed	Qtrly PN and sampling required		YES	4/3/2014	RAA < MCL - Treatment/Blending	
Visalia-12	1610003	Hanford, City of	53320	15509	COMMUNITY	NO	EPA NO. PWS-AO-2006-6028	9/13/2006		YES					Drilled new wells, rehabbed wells	10+ wells exceeded	Qtrly PN and sampling required		YES	7/19/2013	Source(s) Abandoned	
Visalia-12	1610007	Home Garden CSD	1750	453	COMMUNITY		0912008	1/23/2009		YES					Prop. 84 project- NOAA	3 wells exceed	Qtrly PN and sampling required		YES	1/1/2013	RAA < MCL - Treatment Installed	

Water Systems with Arsenic Violations Returned to Compliance																						
Yolo LPA-87	5700514	Bogle Delta Winery	69	3	NTNC	NO	1301031	11/1/2012	YES	YES			7/1/2014	YES	NO		The winery RAA was 13.5 ppb	New solution includes public notification on every sink and hosebib, bottled water delivery contract and map of water cooler locations, employee and visitor training to only use bottled water for consumption, and update to operations and maintenance manual which outlines these procedures.		YES	8/4/2014	Source(s) Reclassification

County Name	County Number	District Water System out of compliance	LPA Water System out of compliance	Water Systems RTC since 2009	Total Water Systems Out-of-Compliance	Shade of County
Alameda	01	0	0	0	0	
Alpine	02	0	0	0	0	
Amador	03	0	0	0	0	
Butte	04	0	0	2	0	
Calaveras	05	0	0	0	0	
Colusa	06	2	0	1	2	
Contra Costa	07	0	3	0	3	
Del Norte	08	0	0	0	0	
El Dorado	09	0	2	0	2	
Fresno	10	12	0	2	12	
Glenn	11	0	0	0	0	
Humboldt	12	0	0	0	0	
Imperial	13	0	1	0	1	
Inyo	14	0	3	2	3	
Kern	15	36	0	14	36	
Kings	16	3	8	5	11	
Lake	17	0	0	0	0	
Lassen	18	0	0	1	0	
Los Angeles	19	1	7	2	8	
Madera	20	3	16	3	19	
Marin	21	0	0	0	0	
Mariposa	22	2	0	0	2	
Mendocino	23	0	0	1	0	
Merced	24	3	0	4	3	
Modoc	25	0	0	0	0	
Mono	26	1	1	1	2	
Monterey	27	0	11	7	11	
Napa	28	0	0	1	0	
Nevada	29	0	0	1	0	
Orange	30	0	0	0	0	
Placer	31	0	0	1	0	
Plumas	32	1	0	1	1	
Riverside	33	0	4	2	4	
Sacramento	34	0	7	3	7	
San Benito	35	1	0	3	1	
San Bernardino	36	1	8	4	9	
San Diego	37	0	1	1	1	
San Francisco	38	0	0	0	0	
San Joaquin	39	0	6	12	6	
San Luis Obispo	40	0	3	0	3	
San Mateo	41	0	0	1	0	
Santa Barbara	42	1	0	0	1	
Santa Clara	43	0	0	0	0	
Santa Cruz	44	0	0	1	0	

Legend



Shasta	45	0	0	1	0	
Sierra	46	1	0	0	1	
Siskiyou	47	0	0	0	0	
Solono	48	0	0	0	0	
Sonoma	49	8	0	13	8	
Stainslaus	50	2	14	1	16	
Sutter	51	4	0	12	4	
Tehama	52	1	2	0	3	
Trinity	53	1	0	0	1	
Tulare	54	8	0	0	8	
Tuolumne	55	0	0	0	0	
Ventura	56	0	0	1	0	
Yolo	57	0	2	2	2	
Yuba	58	0	2	0	2	
Totals		92	101	106	193	

Q